

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING – BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7300-1615: 215

Page 1 of 1

**CATEGORY:** Misc. Devices/Control Unit Accessories

**LISTEE:** Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450  
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

**DESIGN:** Models F220-B6PM and –B6PS detector bases. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** F220-B6PM = 18.9 Vdc – 28Vdc  
F220-B6PS = 9.6Vdc – 28 Vdc

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, rating, and UL label.

**APPROVAL:** Listed as detector bases for use with listee's separately listed fire alarm control units and Models F220-135 series (CSFM Listing No. 7270-1615:108), heat detectors; Models F220-PC series (CSFM Listing No. 7272-1615:107) or Models F220-P series (CSFM Listing No. 7272-1615:106) photoelectric smoke detectors. Refer to listee's Installation Instruction Manual for details.

01-08-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*